

REPORT OF PERFORMANCE

187-91

CLIENT Transformateurs Balteau S.A.,
Beyne-Heusay, Belgium
MANUFACTURER Transformateurs Balteau S.A.,
Beyne-Heusay, Belgium
APPARATUS Current transformer

DESIGNATION CTH 550
SERIAL No. 5138/9102
Balteau order No. 56447

RATINGS ASSIGNED BY THE MANUFACTURER

Voltage	550	kV
Frequency	60	Hz
Short-time withstand current	40	kA
Peak withstand current	113	kA
Duration of short-circuit	3	s
Secondary terminals	6 cores MR	
Primary current	4000	A
Secondary current	5	A
Burden	200	VA
Accuracy class	5 x C800 + 1 x 0.3 B 1.8	

The tests have been carried out in accordance with the client's instructions.

Date of tests 14th May 1991

The performance of the apparatus tested and the observations made during the tests have been recorded in the tables with test results and the oscillograms.

THIS REPORT CONSISTS OF:

Sheets	4
Circuit diagrams	1
Electromagnetic oscillograms	2
Drawings	2
Photographs	3
Information sheet	B70E

© Copyright: Publication or reproduction of the contents of this report in any other form than a complete copy to the letter, is not allowed without our written consent.

N.V. KEMA

H.W. Kempen

Arnhem, 30th May 1991

TYPE OF TEST	SHEET
Internal fault test	3

The tests were witnessed by :

Name

Margreve, O.

Company

Transformateurs Balteau S.A.,
Beyne-Heusay, Belgium

The tests were observed by :

Name

Lusing, M.

Company

N.V. KEMA, Arnhem

Drawings

The following drawings have been included on request of the client.
KEMA has not verified these drawings.

5331033
5331035

CURRENT TRANSFORMER CTH 550
CURRENT TRANSFORMER CTH 550

Photographs

118503
118504
118506

CT before test 910514-2007
CT after test 910514-2007
CT after test 910514-2007

[illegible]

TABLE WITH RESULTS OF INTERNAL-FAULT TESTS

REPORT 187-91		Internal fault test (1)				TEST CIRCUIT S01		SHEET 3							
Condition before tests: Arc Initiation point : see drawing 5331033. Current transformer new. Current transformer mounted in vertical position and filled with oil. Photograph 118503.															
Test 910514-2005: checking of the prospective current.															
Date and test	Test quantities							Physical behaviour							
	Applied voltage kV	Peak value of current kA	Symmetrical current				Duration s	Pressure bar(abs)	Energy MJ	Ignition point	Arc voltage kVpeak	Emission of			
			Begin-ning kA	Middle kA	End kA	Average kA						on	Position	Flame	Gas
910514 2005	12.0	57.5	40.8				0.221								
910514 2007	12.0	57.5	40.6			39.5	0.225		8.85		2.00 max	heavy (2)	heavy		

Condition after tests: Aluminium base, porcelain and aluminium tank: undamaged.

Fire at top of head after the test. Photographs 118504 and 118506.

Ejected oil at the base of the CT.

Hole in aluminium dome of approximately 500 mm. The top aluminium sheet of the dome was torn into two pieces which fell on the ground within a radius of 3 m from the base of the CT. One of these pieces was found at 3 m from the CT while the second piece bounced and slid on the metal floor of the lab to stop at 12 m from the CT base.

- (1) The purpose of the test is to observe the behaviour of the current transformer with paper mineral oil insulation when an internal insulation fault occurs.
 (2) Emission of flame 9 ms after initiation of current.

REPORT 187-91		CALIBRATION OF ELECTROMAGNETIC OSCILLOGRAM				SHEET 4	
Time marking ▶		10 ms	ms	ms	ms	ms	
Test		Test	Test	Test	Test	Test	
Trace ▼	Phase ▼	910514 2005,2007					
CURRENT OPENING COIL momentary A/mm							
CURRENT CLOSING COIL momentary A/mm							
VOLTAGE momentary kV/mm							
2		0.905					
CURRENT momentary kA/mm							
3		2.35					
AMPLIFIED VOLTAGE momentary V/mm							
4		99					
AMPLIFIED CURRENT momentary A/mm							
$I^2 t$ $10^3 \times A^2 s/mm$							
POWER MW/mm							
ENERGY MJ/mm							
5		0.334					
PRESSURE bar/mm							

☐ Trace No. 1 is indicated on each oscillogram. Traces are numbered from top to bottom except for travel recorders. ☐
For practical reasons travel recorder traces bear no number.

TEST-CIRCUIT DIAGRAM

REPORT No. 187-91

TEST CIRCUIT No. S01

CIRCUIT COMPONENTS

G = Generator
 MB = Master Breaker
 MS = Make Switch
 PT = Power Transformer
 R = Resistor
 C = Capacitor
 L = Inductance


T0 = Test Object
 AL = Artificial Line
 AB = Auxiliary Breaker


MEASUREMENTS


U = Voltage Measurement
 I = Current Measurement


Suffix of U and I

L = Low-frequency Oscillograph
 H = Medium-frequency Oscillograph
 H = High-frequency Oscillograph
 LD = Differential measurement with L
 HD = Differential measurement with H
 HD = Differential measurement with H












Insulation fault

- | | | |
|----|------------------------------|------------------|
| 1 | TOP COVER | ALUMINIUM |
| 2 | DIAPHRAGM LEVEL INDICATOR | |
| 3 | DIAPHRAGM | STAINLESS STEEL |
| 4 | HEAD HOUSING | ALUMINIUM |
| 5 | EPOXY CAST RESIN | |
| 6 | CORES AND SECONDARY WINDINGS | IN ALUMINIUM BOX |
| 7 | PRIMARY CONDUCTOR | ALUMINIUM |
| 8 | H V INSULATION | PAPER-OIL |
| 9 | INSULATOR | PORCELAIN |
| 10 | INSULATING OIL | |
| 11 | BASE | ALUMINIUM |
| 12 | FEET | CAST-IRON |
| 13 | SECONDARY TERMINAL BOX | ALUMINIUM |
| 14 | SAMPLING VALVE | STAINLESS STEEL |




MODIFICATIONS		N°Mod.	DATE	3		
1				4		
2				5		

 BALTEAU ENERTEC	CURRENT TRANSFORMER CTH 550				DEMANDE	NOMENC			
	REPertoire :				APP	QC	IDH	PTH	ARC
Beyne-Hausay BELGIQUE	ECHELLE	DESSINE CP	VU	DATE 15.6.90.	REPLACE	REPLACE PAR	PLAN N°	5331033	




STRIKE DISTANCE : 3700 MM
 CREEPAGE DISTANCE : 9900 MM


WEIGHT : 2250 KG
 OIL : 560 L



VIEW BELOW BASE

 BALTEAU ENERTEC		CURRENT TRANSFORMER CTH 550				DEMANDE	NOMENC
REPERTOIRE :		APP	QC	IDH	PTH	ARC	
Debye-Humbert BELGIQUE	ECHELLE 1/30	DESSINE CP	VU	DATE 15.6.90.	REMPLACE	REMPLACE PAR	PLAN N° 5331035


KEMA ©




KEMAL ©

118504

1





1 Certificate of Compliance

A Certificate contains a record of a series of type tests carried out strictly in accordance with a recognized standard. The equipment tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by KEMA. The Certificate is applicable only to the equipment tested. KEMA is responsible for the validity and the contents of the Certificate.

The responsibility for conformity of any apparatus having the same designation as the one tested rests with the manufacturer.

The Certificate contains the essential drawings and a description of the equipment tested. Detailed rules are given in KEMA's Certification procedure.

2 Report of Performance

A Report of Performance contains a record of one or more tests which have been carried out according to the client's instructions. These tests are not necessarily in accordance with a recognized standard. The test results do not verify ratings of the test object.

KEMA issues three types of Reports of Performance:

2.1 *The tests have been carried out strictly in accordance with The apparatus has complied with the relevant requirements.*

This sentence will appear on the front page of a Report of Performance if the tests have been performed in accordance with a recognized standard, but the series of tests does not completely fulfill the requirements for a Certificate of Compliance (for example, if the number of test duties is not a complete series of type tests).

The Report contains verified drawings and a description of the equipment tested. Detailed rules are given in KEMA's Certification procedure. The condition of the test object after the tests is assessed and recorded in the Report.

2.2 *The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on*

This sentence will appear on the front page of a Report of Performance if the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer.

Verification of the drawings (if submitted) and assessment of the condition after the tests is only done at the client's request.

2.3 *The tests have been carried out according to the client's instructions.*

This sentence will appear on the front page of a Report of Performance if the tests, test procedure and/or test parameters are not in accordance with a recognized standard.

3 Standards

When reference is made to a standard, and the date of issue is not stated, this applies to the latest issue, including amendments which have been officially published prior to the date of the tests.

4 Accuracy of measurement

In the table of test results the measured quantities are given in three digits. This method of presentation does not indicate an accuracy. The guaranteed uncertainty in the figures mentioned, taking into account the total measuring system, is less than 5%, unless mentioned otherwise.

5 Qualified by STERLAB

The De Zoeten Laboratorium has been entered in the STERLAB register for laboratories under Nr. 20 for the testing services as defined in the Field of Accreditation.

The accreditation is applicable to tests performed in accordance with IEC, ANSI and European standards, recorded in test documents items 1 and 2.1 above.

The accreditation is carried out in accordance with European Standard 45001, based on ISO/IEC Guides 25 and 38.

