

client**ALSTOM T&D - Noventa di Piave (Venezia), Italy****equipment under test**

One pole of disconnector 550 kV type S2DAT-550/3150

tests performedRadio Interference Voltage (R.I.V.) test;
Dielectric tests.**normative documents**

IEC 60129, 1998 - IEC 60694, 1996 and Client's requests

receipt date of the sample

October 30, 2000

test date

from November 15, 2000

to November 22, 2000

the test results relate only to the sample tested

this document shall not be reproduced except in full without the written approval of CESI
and of the accreditation body, if any**no. of pages**

27

no. of pages annexed

3

issue date

March 21, 2001

prepared

PeC/TEST - C. Del Giorgio


CESI
CENTRO ELETROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio**verified**

PeC/TEST - D. Pirola, A. Cattaneo

approved

PeC/TEST - V. Scarioni

tests witnessed by: Mr. Piccoli - ALSTOM T&D

identification of the object: effected

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered **A1/014250 no.1 to 4** are annexed to this document.

the data necessary to permit repetition of the tests are contained in the document marked:
AT-A0/037225

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : **peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$**
- dielectric tests with alternating voltage : **voltage (rms): $\pm 3\%$**

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


activity code: 29186B

keywords: 12015R - 23450P - 31040K - 42010U - 53001D - 62501B

| contents | page | test date |
|---|---------|----------------------|
| rated characteristics of the tested object assigned by the Client | 4 | |
| Test setting | 5 | |
| Dielectric test conditions | 6 | |
| Measurement of the R.I.V. | 7 ÷ 10 | November 15-16, 2000 |
| Determination of the 50% discharge voltage with the "up and down" test method | 11 | November 16, 2000 |
| Dry switching impulse withstand voltage test | 12 | November 16-17, 2000 |
| Dry lightning impulse withstand voltage test (combined voltage test) | 13 | November 17, 2000 |
| Dry switching impulse withstand voltage test (combined voltage test) | 14 | November 17, 2000 |
| Dry lightning impulse withstand voltage test (combined voltage test) | 15 | November 17, 2000 |
| Dry lightning impulse withstand voltage test | 16 | November 17, 2000 |
| Dry power frequency withstand voltage test | 17 | November 17, 2000 |
| Dry power frequency withstand voltage test in out-of-phase condition | 18 | November 20, 2000 |
| Wet switching impulse withstand voltage test | 19 | November 21, 2000 |
| Wet switching impulse withstand voltage test (combined voltage test) | 20 | November 21, 2000 |
| Circuits A062 - A102 - A006 - A045 - A065 - A064 | 21 ÷ 26 | |
| Panoramic view | 27 | |
| Pages annexed | | |
| - charts from test report AT-A0/037225 (total pages no.3) | | |
| Reference document annexed | | |
| - drawings identified by CESI and numbered A1/014250 no.1 to 4 | | |

Rated characteristics of the tested object assigned by the Client


| | |
|-------------------------------------|----------------|
| disconnector | ALSTOM |
| manufacturer | S2DAT-550/3150 |
| type | DIN-xxxxx |
| drawing no. | ----- |
| serial number | 550 kV |
| voltage | 3150 A |
| normal current | 50 Hz |
| frequency | 1550 kV |
| lightning impulse withstand voltage | 1175 kV |
| switching impulse withstand voltage | 710 kV |
| power frequency withstand voltage | 63 kA |
| short-time withstand current | 160 kA |
| peak withstand current | 3 s |
| short-circuit duration | |

Test setting

all the dimensions are given in mm

Dielectric tests

test configurations

**Test condition in general case**

| Test condition | Switching device | Voltage applied to | Earth connected to |
|----------------|------------------|--------------------|--------------------|
| 1 | closed | Aa | F |
| 2 | open | A | a F |
| 3 | open | a | A F |

Power - frequency test conditions for longitudinal insulation

| Test condition | Voltage applied to | Earth connected to |
|----------------|--------------------|--------------------|
| 4 | A and a | F |

Impulse test conditions for longitudinal insulation

| Test condition | Main part | Complementary part | Earth connected to |
|----------------|--------------------|--------------------|--------------------|
| | Voltage applied to | | |
| 5 | A | a | F |
| 6 | a | A | F |

Measurement of the radio interference level (CISPR 16.1 1993; CISPR 18.2 1986 Standards)

test object: background noise (without test object)
test circuit: A062-A102-A006 (for the A determination)
test arrangement: ---
instrument: PMM 8010

| atmospheric conditions | | | |
|------------------------|----------------------|----------------------|--------|
| b kPa | t _d °C | t _w °C | h % |
| 100,0 | 13,5 | 10,0 | 64,0 |

frequency: 1,0 MHz

a: instrument reading [dB / 1 μ V / 50 Ω]

b: corrected and reported value $b = a + 15.5 + A$ [dB / $1\mu\text{V}$ / 300Ω]

c: reported and corrected value $c = 10^{b/20} [\mu\text{V}]$

A = 1 dB attenuation

date: November 15, 2000

Test Report

Measurement of the radio interference level (CISPR 16.1 1993; CISPR 18.2 1986 Standards)

test object: One pole of disconnector 550 kV type S2DAT-550/3150
test circuit: A062-A102-A006 (for the A determination)
test arrangement: Test condition no.3 to page 6
instrument: PMM 8010

| atmospheric conditions | | | |
|------------------------|----------------|----------------|------|
| b | t _d | t _w | h |
| kPa | °C | °C | % |
| 100,4 | 14,0 | 10,0 | 60,0 |

frequency: 1,0 MHz

a: instrument reading [dB / 1 μ V / 50 Ω]

b: corrected and reported value $b = a + 15.5 + A$ [dB /1 μ V/ 300 Ω]

c: reported and corrected value $c = 10^{b/20} [\mu\text{V}]$

A = 1 dB attenuation

date: November 16, 2000

NOTE: r.i.v. characteristics in chart no.1

Test Report

Measurement of the radio interference level (CISPR 16.1 1993; CISPR 18.2 1986 Standards)

test object: One pole of disconnector 550 kV type S2DAT-550/3150
test circuit: A062-A102-A006 (for the A determination)
test arrangement: Test condition no.2 to page 6
instrument: PMM 8010

| atmospheric conditions | | | |
|------------------------|----------------|----------------|------|
| b | t _d | t _w | h |
| kPa | °C | °C | % |
| 100,10 | 14,5 | 11,5 | 69,8 |

frequency: 1,0 MHz

a: instrument reading [dB / 1 μ V / 50 Ω]

b: corrected and reported value $b = a + 15.5 + A$ [dB /1 μ V/ 300 Ω]

c: reported and corrected value $c = 10^{b/20} [\mu\text{V}]$

A = 1 dB attenuation

date: November 16, 2000

NOTE: r.i.v. characteristics in chart no.2

Test Report

Measurement of the radio interference level (CISPR 16.1 1993; CISPR 18.2 1986 Standards)

test object: One pole of disconnector 550 kV type S2DAT-550/3150
test circuit: A062-A102-A006 (for the A determination)
test arrangement: Test condition no.1 to page 6
instrument: PMM 8010

| atmospheric conditions | | | |
|------------------------|----------------|----------------|------|
| b | t _d | t _w | h |
| kPa | °C | °C | % |
| 100,10 | 14,5 | 11,5 | 69,8 |

frequency: 1,0 MHz

a: instrument reading [dB / 1 μ V / 50 Ω]

b: corrected and reported value $b = a + 15.5 + A$ [dB / μ V / 300 Ω]

c: reported and corrected value $c = 10^{b/20} [\mu\text{V}]$

A = 1 dB attenuation

date: November 16, 2000

NOTE: r.i.v. characteristics in chart no.3

Determination of the 50% discharge voltage with the "up and down" test method

Dry switching impulse.

test object: One pole of disconnector 550 kV type S33CDT-550/3150

test circuit:

note:

Dry switching impulse withstand voltage test

One pole of disconnector 550 kV type S2DAT-550/3150

test object:

test circuit:

note:



Test Report

AT-A1/009027

Determination of the 50% discharge voltage with the "up and down" test method

Dry switching impulse (combined voltage test).

One pole of disconnector 550 kV type S2DAT-5500/3 150 test object:

A04 test circuit:

note: power frequency applied on terminal a

Dry switching impulse withstand voltage test (combined voltage test)

One pole of disconnector 550 kV type S2DAT-550/3150

לען תומכו

test circuit:

| test condition | polarity | switching impulse peak voltage | | | power frequency peak voltage | | | test result | test date |
|----------------|----------|--------------------------------|-------------------|-------------|------------------------------|-------------------|-------------|-------------|-----------|
| | | required | correction factor | applied | required | correction factor | applied | | |
| | | kV_{peak} | K_t | kV_{peak} | kV_{peak} | K_t | kV_{peak} | no. | no. |
| 6 | negative | 900 | 0,985 | 887 | + 450 | 0,985 | + 443 | 15 | 0 |
| 5 | positive | 900 | 0,985 | 887 | - 450 | 0,985 | - 443 | 15 | 0 |
| 5 | negative | 900 | 0,985 | 887 | + 450 | 0,985 | + 443 | 15 | 0 |

note:

Dry lightning impulse withstand voltage test (combined voltage test)

test object: One pole of disconnector 550 kV type S2DAT-550/3150

test circuit:

A065

| test condition | polarity | lightning impulse peak voltage | | | power frequency peak voltage | | | test result | test date |
|----------------|----------|--------------------------------|-------------------|-------------|------------------------------|-------------------|---------|-------------|-----------|
| | | required | correction factor | applied | required | correction factor | applied | | |
| | | | | kV_{peak} | K_t | kV_{peak} | K_t | | |
| 5 | negative | 1550 | 0,975 | 1510 | +315 | 0,975 | +307 | 15 | 0 |
| 5 | positive | 1550 | 0,975 | 1510 | -315 | 0,975 | -307 | 15 | 0 |
| 6 | negative | 1550 | 0,975 | 1510 | +315 | 0,975 | +307 | 15 | 0 |
| 6 | positive | 1550 | 0,975 | 1510 | -315 | 0,975 | -307 | 15 | 0 |

note:

Test Report

CESI [ESI]
Testing Services

Testing Services

AT-A1/009027

Dry lightning impulse withstand voltage test

test object: One pole of disconnector 550 kV type S2DAT-550/3150

test circuit: A045

| test condition | requested voltage | correction factor | positive polarity | | | test result | requested voltage | negative polarity | | | test result | test date |
|----------------|--------------------|-------------------|--------------------|------------------|---------------|--------------------|-------------------|--------------------|-----------------|------------------|-------------|-------------------|
| | | | applied voltage | applied impulses | flashover no. | | | correction factor | applied voltage | applied impulses | | |
| no. | kV _{peak} | K | kV _{peak} | no. | no. | kV _{peak} | K | kV _{peak} | no. | no. | | |
| 1 | 1550 | 0,975 | 1511 | 15 | 0 | withstand | 1550 | 0,975 | 1511 | 15 | 0 | November 20, 2000 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

note:

Dry power frequency withstand voltage test

test object: One pole of disconnector 550 kV type S2DAT-550/3150

test circuit: A062

| test condition | required (U) | correction factor K _r | voltage | | test duration | test result | test date |
|----------------|------------------|-------------------------------------|---------|---|---------------|-------------------|-----------|
| | | | | applied (U × K _r) kV _{ms} | | | |
| no. | kV _{ms} | | | | | | |
| 1 | 620 | 0,994 | 616 | 60 | withstand | November 20, 2000 | |
| 2 | 620 | 0,994 | 616 | 60 | withstand | November 20, 2000 | |
| 3 | 620 | 0,994 | 616 | 60 | withstand | November 20, 2000 | |
| 1 | 620 | 0,994 | 616 | 72 | withstand | November 20, 2000 | |
| 2 | 620 | 0,994 | 616 | 72 | withstand | November 20, 2000 | |
| 3 | 620 | 0,994 | 616 | 72 | withstand | November 20, 2000 | |

note:

Dry power frequency withstand voltage test in out-of-phase condition**test object:**

One pole of disconnector 550 kV type S2DAT-550/3150

test circuit:

A064

| test condition | voltage | | test duration | | test result | test date |
|----------------|---------------|-------------------------------|---------------------------|----|-------------|-------------------|
| | required U | correction factor K_t | applied $U \times K_t$ | s | | |
| 4 | 800 | 0,995 | 796 | 60 | withstand | November 20, 2000 |
| 4 | 800 | 0,995 | 796 | 72 | withstand | November 20, 2000 |
| | | | | | | |
| | | | | | | |
| | | | | | | |

note: applied voltage:on terminal A = 496 kV_{rms}on terminal a = 300 kV_{rms}

Wet switching impulse withstand voltage test

test object: One pole of disconnector 550 kV type S2DAT-550/3150

test circuit: A045

| | | | | precipitation conditions | | water resistivity $\Omega \times m$ | |
|------------|--|--|--|--------------------------|--------|--|----------------------------------|
| | | | | top | center | bottom | water temperature $^{\circ}C$ |
| vertical | | | | 1,4 | -- | 1,5 | |
| horizontal | | | | 1,2 | -- | 1,2 | 12,0 |
| | | | | | | | 100,0 |

| test condition | requested voltage | correction factor | positive polarity | | test result | requested voltage | negative polarity | | test result | test date |
|----------------|-------------------|-------------------|--------------------|----|-------------|-------------------|-------------------|------------------|-------------|-----------|
| | | | kV _{peak} | K | | | applied voltage | applied impulses | flashover | |
| 1 | 1175 | 1,000 | 1175 | 15 | 0 | withstand | 1175 | 1,000 | 1175 | 0 |
| 2 | 1175 | 1,000 | 1175 | 15 | 0 | withstand | 1175 | 1,000 | 1175 | 0 |
| 3 | 1175 | 1,000 | 1175 | 15 | 0 | withstand | 1175 | 1,000 | 1175 | 0 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |

note:

Wet switching impulse withstand voltage test (combined voltage test)**test object:**

One pole of disconnector 550 kV type S2DAT-550/3150


test circuit:

A065

| | | precipitation conditions | | | water resistivity Ω × m |
|----------|------------|--------------------------|--------|--------|----------------------------|
| | | top | center | bottom | |
| vertical | | 1,4 | -- | 1,5 | 100,0 |
| | horizontal | 1,2 | -- | 1,2 | |

| test condition | polarity | switching impulse peak voltage | | power frequency peak voltage | | applied impulses | flashover | test result | test date |
|----------------|----------|--------------------------------|-------------------|------------------------------|-------------------|--------------------|-----------|-------------|-------------------|
| | | required | correction factor | required | correction factor | | | | |
| 5 | negative | 900 | K _t | kV _{peak} | K _t | kV _{peak} | no. | no. | November 21, 2000 |
| 5 | positive | 900 | 1,000 | 900 | +450 | 1,000 | +450 | 15 | 0 |
| 6 | negative | 900 | 1,000 | 900 | -450 | 1,000 | -450 | 15 | 0 |
| 6 | positive | 900 | 1,000 | 900 | +450 | 1,000 | +450 | 15 | 0 |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

note:

circuit A062**power frequency measuring circuit**

TV_2 : voltage reducer

V_2 : voltmeter

f.o : electrooptical link for the direct reading of the voltage


V_3 : voltmeter

TV_1 : voltage reducer

V_1 : voltmeter

circuit A102

measurement of radiointerference level (Standard CISPR 16 1987, CISPR 18.2 1986)



F : high voltage filter

C_k : coupling capacitor

B : low voltage unit

R : low voltage unit resistance (250Ω)



L : 50 Hz low-impedance inductor

M : measuring instrument PMM 8010

R_i : internal resistance of the measuring instrument (50Ω)


circuit A006

measurement of the radiointerference level (CISPR 16 1987, CISPR 18.2 1986 Standards)
attenuation of the measuring circuit (A)



I : current impulse generator

| V_{m1} | V_{m2} | A $V_{m2} - V_{m1}$ |
|----------|----------|------------------------|
| [dB] | [dB] | [dB] |
| 42,0 | 43,0 | 1 |

circuit A045**impulse test circuit**

C_g : Impulse generator capacitance

R_f : Front resistor

R_c : Tail resistor


C_c : Load capacitance

D : Divider type RC series

R_1 : Matching impedance

VC : Peak voltmeter

CRO: Oscilloscope

circuit A065**circuit for combined voltage test L.I./50 Hz**

C : capacitor

power frequency measuring circuit - circuit A061

f.o. : electrooptical link for the direct reading of the voltage

V₃ : voltmeter

TV₁ : voltage reducer


V_{1O} : voltmeter

impulse voltage measuring system - circuit A045

D : divider RC series

V_c : peak voltmeter

CRO: oscilloscope

circuit A064

measuring circuit for test in out-of-phase condition (plant P170)

power frequency measuring circuit - circuit A061

TV₁ : voltage reducer

V_1 : voltmeter

T : booster transformer

f.o. : electrooptical link for the direct reading of the voltage

V_3 : voltmeter

R_{AT} : protection resistor

power frequency measuring circuit - circuit A012

G : gap protection 1500 mm

D : capacitive voltage divider

CRO: oscilloscope

TV₂ : voltage reducer

V_2 : voltmeter

T : booster transformer

TV₁ : voltage reducer

V_1 : voltmeter

Panoramic view







Photo no. 1



S2DAT 550 kV - config. 3



S2DAT 550 kV - config. 2



CESI TEST

A0/037225

chart n.2

S2DAT 550 kV- config. 1

